

2.17FACTORY FINISH

- A. All exterior galvanized steel surfaces are to be hand acid etched, chemically cleaned, coated with proper primer, then painted with two 100% covering coats of eggshell enamel with colour as selected from the paint manufacturer's standard colour range. Paint (finish) louvers to match unit colour. Supply four (4) litres of touch-up paint for each unit.

2.18ACCEPTABLE MANUFACTURES AND SUPPLIERS

- A. Acceptable manufactures and suppliers are as follows:

1. Air handling units

- (A) Haakon industries
(B) Racan carrier co.
(C) Ingenia technologies inc.

 (D) Mafna

(E) Scott springfield

(F) Ventrol

2. Fans

- (A) Twin city fan & blower co.
(B) Loren cook

3. Heat transfer coils

- (A) Aerofin canada services inc.
(B) Heatcraft inc.
(C) Mcquay

4. Electric unit heaters

- (A) Indeeco
(B) Thermolec manufacturing ltd.
(C) Chromalox.
(D) Supply per requirements of div16 c/w with built-in thermostats.

5. Filters

- (A) Camfilfarr inc.