

1. Article 1.12 23 33 00 – Duct System Dampers and Accessories

.1 Add the following paragraph to the article:

1.12.15 Provisions for Smoke Dampers

.1 Fail-safe, opposed blade, galvanized steel (unless otherwise specified) smoke dampers, ULC listed and labelled, leakage Class I smoke rated, normally closed, Type "B" or "C" as required, and complete with a factory installed and tested 115 volt electric actuator, jamb seals, and linkage is to be concealed in the frame, out of the airstream. Smoke dampers are to meet requirements of CAN/ULC-S112.1-10, and NFPA 90A, 92A, and 92B.

.2 Acceptable Manufacturers:

- .1 Nailor Industries Series 1210;
- .2 Price Industries Ltd.;
- .3 NCA Manufacturing Ltd.;
- .4 Ruskin Co.
- .5 Approved Equal.

2. Article 1.28 23 73 13 –Air Handling Units – Semi-Custom Indoor

.1 Revise the title of the article to read: “23 75 00 – Air Handling Units – Custom Made”

.2 Revise paragraph 1.28.1 to read “Provisions for Custom Made Air Handling Units” revise specification for air handling units as per the attached document.

.3 Revise paragraph 1.28.2 to read as follows:

.1 Acceptable Unit manufacturers:

- .1 Venmar CES
- .2 Haakon Industries (Canada) Ltd.;
- .3 Ventrol;
- .4 MAFNA Air Technologies Inc.;
- .5 Engineered Air;
- .6 Ingenia Technologies Inc.

.2 Acceptable components as follows:

- .1 fans: Twin City Fan and Blower, Loren Cook