

.10 **Acceptable Manufacturers**

- .1 For individual components, the following manufacturers will be considered equal subject to the requirements of Clause "Materials and Equipment":

Fans	Twin City Cook Greenheck New York Blower PennBarry
------	--

Coils	Daikin Areofin Engineered Air Unifin
-------	---

Energy Recovery Wheels	SG America Innergytech Semco Thermotech
------------------------	--

Dampers	Tamco Ruskin
---------	-----------------

Humidifiers	Dri-Steem Nortec Armstrong
-------------	----------------------------------

- .2 The following manufacturers of the above equipment will be considered equal, subject to requirements of Clause "Material and Equipment":

Engineered Air
Haakon
Ingenia
Mafna
TMI Climate Solutions

2.3 **ROOFTOP ELEVATOR PRESSURIZATION UNIT (DRAWING REFERENCE RTU-ELP)**

.1 **General**

- .1 Provide Haakon rooftop air handling unit, custom designed, factory fabricated and shipped to the site. Rooftop air handling unit will involve combinations of the following components: supply fan, outside air dampers, heating coils, access sections, filters and outside air sections. Refer to Equipment Schedule on the Drawings for capacities. Be responsible for the complete design and fabrication of the units in accordance with the Specifications. Design the units to suit outdoor conditions with the arrangements and space allocations shown on the Drawings. Use unit designed for outdoor installation. Provide a single point electrical connection for all motors. Unit to be painted a custom colour. Colour to be selected during shop drawings.