

1. Comply with ARI 210/240 and ARI 340/360 for testing and rating energy efficiencies for units.
 2. Comply with ARI 270 for testing and rating sound performance for units.
- B. ASHRAE Compliance:
1. Comply with ASHRAE 15 for refrigerant system safety.
 2. Comply with ASHRAE 33 for methods of testing cooling and heating coils.
 3. ASHRAE 90.1 for unit energy efficiency.
- C. NFPA Compliance: Comply with NFPA 90A and NFPA 90B.
- D. Units shall be ETL-approved. Gas train on unit furnace shall be UL approved.
- E. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Deliver equipment to the job site packaged and protected for overland trucking and for storing the equipment outside exposed to the weather. Cover duct connection openings with plywood or sheet metal caps.

PART 2 - PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Acceptable Manufacturers, subject to compliance with requirements, provide products of one of the following:
1. Air Enterprises
 2. Governair Corp.
 3. Ingenia Technologies.
 4. MAFNA Air Technologies.